

CERTIFICATE

No. 000011/03

In accordance with the **CertAlarm** Rules
and Certification System 5, as defined in ISO / IEC Guide 67,
we Telefication B.V. certify that the product

BMS-O IP/GPRS

is in conformity with the following standard(s)

- | | |
|--------------------|----------------|
| - EN 50130-4: | December, 1995 |
| - EN 50130-4/A1: | April, 1998 |
| - EN 50130-4/A2: | January, 2003 |
| - EN 54-21: | May, 2006 |
| - EN 54-4: | A1, 2002 |
| - EN 54-4: | A2, 2006 |
| - EN 54-4:1997/AC: | February, 1999 |

ASB-Security B.V.

Boschdijk 720
5624 CL Eindhoven
Netherlands

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

13 June 2014

Signed on behalf of Telefication B.V.
10 January 2014

i.o.



W.J.M. Jong
Manager Product Certification



Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000011/03 - Annex No 1

Takes into account the following product and variants:

- Product description: IP/GPRS Alarm Transmission Equipment
- Trademark: certiFireOne
- Type Designation: BMS-O IP/GPRS
- Hardware version: Rev. V2.0
- Software version: 1.19

- Product description: IP/GPRS Alarm Transmission Equipment
- Trademark: certiFireOne
- Type Designation: DME128 IP/GPRS
- Hardware version: Rev. V2.0
- Software version: 1.19

The optional features of the specifications that are included in the product and test report:

Two alarm transmission paths are provided:

(EN 54-21 Type 1 and Type 2)

Type 1: With a DSL router; using the fixed IP VPN network

Type 2: The secondary (backup) ATP; using GPRS

Performance classification of the transmission module

Type 1: ATS5 (D4, M4,T5, S0, I0)

Type 2: ATS4 (D4, M3,T2, S0, I0)


Availability is dependent upon the network provider and shall be A4.

GENERAL CLASSIFICATION

- Equipment security Grade 3
- Equipment Environmental class II
- Equipment class Fixed

Test Report Numbers:

- Telefication B.V.: 20071298802, 21 July 2008
- Telefication B.V.: 20082699800 rev 1, 15 April 2010
- Telefication B.V.: 20103249200, 30 August 2010



Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000011/03 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

DISCLAIMER

The validity of this certificate is limited to products, which are equal to the one(s) examined.