

Certificate

of

Type-examination

Additional certificate N°: 06229019/AA/01

Telefication declares that the stated alarm equipment complies with the Technical specifications as listed in Annex 2 of this certificate.

Product description: **I/O Module**
Trademark: **MuSDO**
Family name: **--**
Type designation: **MIO-8/2**
Serial N°: **-**
Software release N°: **-**

Manufacturer: **ASB Technology BV**
Address: **De Ronde 15A**
City: **5683 CZ Best**
Country: **The Netherlands**

This additional certificate is granted to:

Name: **ASB Technology BV**
Address: **De Ronde 15A**
City: **5683 CZ Best**
Country: **The Netherlands**

This additional certificate has TWO Annexes. Expiry date: 22 May 2009.

Zevenaar, 22 May 2006



M.H. Koop
Manager Certification



Remarks and observations

The following conditions are applicable:

- Equipment Security grade: 3
- Equipment Environmental class: II
- Equipment class: Fixed

- This certificate is only valid when the MIO-8/2 is integrated within MuSDO MAP, CCS64, CCS128 or CCS256.

- According to prEN 50131-1:2004, this equipment can be applied in installed systems up to and including security grade 3.

Documentation lodged for the (additional) type-examination

Testreports:

- Telefication: 99654080, 11 May 2006
- Telefication: 99654020, 11 May 2006
- DARE: 06C00427RPT01, 11 April 2006
- Telefication: 99654050, 22 December 2005

Product documentation:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual
- Installation manual

Technical standards and specifications

- EN 50130-4 June 1995 A1:1998, A2:2003
- EN 50130-5 December 1998
- EN 50131-3 July 2003

Technical features and characteristics

The product includes the following features and characteristics:

- Not specified