

Certificate

of

Type-examination

Additional certificate No: 06229020/AA/01

Telefication declares that the stated alarm equipment complies with the Technical specifications as listed in Annex 2 of this certificate.

Product description: Power Supply

Trademark: MuSDO

Family name: --

Type designation: MPS-3A

Serial N°: -

Software release N°: -

Manufacturer: ASB Technology BV

Address: De Ronde 15A
City: 5683 CZ Best
Country: The Netherlands

This additional certificate is granted to:

Name: ASB Technology BV Address: De Ronde 15A

City: 5683 CZ Best
Country: The Netherlands

This additional certificate has TWO Annexes. Expiry date: 22 May 2009.

Zevenaar, 22 May 2006

M.H. Koop Manager Certification PRODUCTS RVA C 224



Annex 1 to Certificate of Type-examination Number: 06229020/AA/01

22 May 2006 Annex 1, Page 1 of 1

Remarks and observations

The following conditions are applicable:

Equipment Security grade: 3Equipment Environmental class: II

Equipment class: Fixed

- This certificate is only valid when the MPS-3A is integrated within MuSDO MAP, CCS64, CCS128 or CCS256.
- According to prEN 50131-1:2004, this equipment can be applied in installed systems up to and including security grade 3



Annex 2 to Certificate of Type-examination Number: 06229020/AA/01

22 May 2006 Annex 2, Page 1 of 1

Documentation lodged for the (additional) type-examination

Testreports:

Telefication: 99654080, 11 May 2006
Telefication: 99654081, 11 May 2006
Telefication: 99654020, 11 May 2006
DARE: 06C00427RPT01, 11 April 2006
Telefication: 99654050, 22 December 2005

Product documentation:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual
- Installation manual

Technical standards and specifications

- EN 50130-4 June 1995 A1:1998, A2:2003

- EN 50130-5 December 1998

- EN 50131-6 May 1998 C1

Technical features and characteristics

The product includes the following features and characteristics:

Not specified